



# FAN MAINTENANCE

## BELT DRIVE FANS

Belts stretch and wear over time and should be checked periodically for wear and tightness.

## PERIODIC MAINTENANCE

For heavy usage (24hr operation, high ambient temperatures, high vibration environments etc.) manufacturers recommend 3-6 month maintenance intervals, to avoid unnecessary downtime.

## DIRECT DRIVE FANS

Direct drive exhaust fans should be inspected annually for worn, bent, damaged, malfunctioning or missing parts.



## SCHEDULE YOUR SERVICE TODAY

Steel Nation's expert team of Greenheck certified technicians offers annual and semi-annual fan maintenance on all makes and models of fans. This service includes a thorough inspection of fan system components including belts, bearings, motors, fan housings, propellers, fasteners, torque valves and voltage and amperage checks. Our inspectors will check for worn, bent, damaged, malfunctioning or missing parts. Belts will be changed and bearings lubricated with every belt drive fan service.

We are currently scheduling for spring. To schedule maintenance contact me for a quote and available dates.



Jordan Millorino  
Project Coordinator  
jmillorino@steelnation.com  
100 Southpointe Square Lane  
Canonsburg, PA 15317  
(P)724-225-2202 x143

Ryan M. Helbling  
Director- Facility Services  
rhelbling@steelnation.com  
100 Southpointe Square Lane  
Canonsburg, PA 15317  
(P)724-225-2202 (C)724-255-3805